




AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Dialight Corporation	Manufacturer:	Dialight Corporation
Address:	1501 Route 34 South Farmingdale, NJ 07727	Address:	Calle Lirios S/N Colonia Carlos Pacheco Ensenada, B.C. Mexico B.C. Mexico 22830
Country:	USA	Country:	Mexico
Contact:	Anthony Russo	Contact:	Angel Escamilla
Phone:	(732) 751-5845	Phone:	52.646.156.7080
FAX:	(732) 751-3145	FAX:	NA
Email:	arusso@dialight.com	Email:	Aescamilla@diliaght.com
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Cortland, NY		
Control Number:	<u>3081714</u>	Authorized by:	 _____
			for Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	UL Standard for Safety Luminaires for Use in Hazardous (Classified) Locations, UL 844 13th Edition Issued June 29, 2012
	Electric Luminaires for Use in Hazardous Locations, CSA C22.2 No. 137-M1981, General Instruction No. 3 November 1982, Reaffirmed 2009
	Enclosures for Use in Class II Groups E, F, and G Hazardous Locations, CSA C22.2 No. 25-1966, General Instruction No. 1 September 1966, Reaffirmed 2009



AUTHORIZATION TO MARK


Product:	LED Luminaire For Use In: Class I Div 1 Groups BCD Class II Div 1 Groups EFG Or Class I Div 1 Groups CD Class II Div 1 Groups EFG Ambient Temperature Range: -40°C to +65°C T-Code: T4A (120°C) Or Ambient Temperature Range: -40°C to +45°C T-Code: T5 (100°C)
Brand Name:	SafeSite Generation II HZ-C/F/P-Y-Z-A-B
Models:	HZ - Product code C/F/P - CID1/CIID1/Group B Y - Lumens Z - LED Color A - Voltage, 100-277V / 347-480VAC / 24-48VDC all Fully Potted B - Option



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Dialight Corporation	Manufacturer:	Dialight Europe LTD
Address:	1501 Route 34 South Farmingdale, NJ 07727	Address:	Exning Road, Newmarket Suffolk, UK CB80AX
Country:	USA	Country:	UK
Contact:	Anthony Russo	Contact:	QC Department
Phone:	(732) 751-5845	Phone:	4.40116E+13
FAX:	(732) 751-3145	FAX:	NA
Email:	arusso@dialight.com	Email:	trevor.mallett@dialight.com
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Cortland, NY		
Control Number:	<u>4001646</u>	Authorized by:	 _____
			for Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	UL Standard for Safety Luminaires for Use in Hazardous (Classified) Locations, UL 844 13th Edition Issued June 29, 2012
	Electric Luminaires for Use in Hazardous Locations, CSA C22.2 No. 137-M1981, General Instruction No. 3 November 1982, Reaffirmed 2009
	Enclosures for Use in Class II Groups E, F, and G Hazardous Locations, CSA C22.2 No. 25-1966, General Instruction No. 1 September 1966, Reaffirmed 2009



AUTHORIZATION TO MARK


Product:	LED Luminaire For Use In: Class I Div 1 Groups BCD Class II Div 1 Groups EFG Or Class I Div 1 Groups CD Class II Div 1 Groups EFG Ambient Temperature Range: -40°C to +65°C T-Code: T4A (120°C) Or Ambient Temperature Range: -40°C to +45°C T-Code: T5 (100°C)
Brand Name:	SafeSite Generation II HZ-C/F/P-Y-Z-A-B
Models:	HZ - Product code C/F/P - CID1/CIID1/Group B Y - Lumens Z - LED Color A - Voltage, 100-277V / 347-480VAC / 24-48VDC all Fully Potted B - Option



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Dialight Corporation	Manufacturer:	Dialight Corporation
Address:	1501 Route 34 South Farmingdale, NJ 07727	Address:	315 Industrial Dr Roxboro, NC 27573-6181
Country:	USA	Country:	USA
Contact:	Anthony Russo	Contact:	Rudy Lopez
Phone:	(732) 751-5845	Phone:	336.597-2291
FAX:	(732) 751-3145	FAX:	NA
Email:	arusso@dialight.com	Email:	rlopez@dialight.com
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Cortland, NY		
Control Number:	<u>4001632</u>	Authorized by:	
			for Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	UL Standard for Safety Luminaires for Use in Hazardous (Classified) Locations, UL 844 13th Edition Issued June 29, 2012
	Electric Luminaires for Use in Hazardous Locations, CSA C22.2 No. 137-M1981, General Instruction No. 3 November 1982, Reaffirmed 2009
	Enclosures for Use in Class II Groups E, F, and G Hazardous Locations, CSA C22.2 No. 25-1966, General Instruction No. 1 September 1966, Reaffirmed 2009



AUTHORIZATION TO MARK

Product:	LED Luminaire For Use In: Class I Div 1 Groups BCD Class II Div 1 Groups EFG Or Class I Div 1 Groups CD Class II Div 1 Groups EFG Ambient Temperature Range: -40°C to +65°C T-Code: T4A (120°C) Or Ambient Temperature Range: -40°C to +45°C T-Code: T5 (100°C)
Brand Name:	SafeSite Generation II HZ-C/F/P-Y-Z-A-B
Models:	HZ - Product code C/F/P - CID1/CIID1/Group B Y - Lumens Z - LED Color A - Voltage, 100-277V / 347-480VAC / 24-48VDC all Fully Potted B - Option