

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product	HighBay luminaires with LED light source
Name and address of the applicant	Dialight Corporation 1501 Route 34 South Farmingdale, New Jersey NJ 07727 United States of America
Name and address of the manufacturer	Dialight Corporation 1501 Route 34 South Farmingdale, New Jersey NJ 07727 United States of America
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 SANMINA SCI SYSTEMS DE MEXICO S.A. DE C.V. Carretera Guadalajara-Chapala Km 15.5 No. 29 45640 Tlajomulco de Zuñiga Jalisco Mexico
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	100-277 Vac, 120-250 Vdc, 0-50/60 Hz, 42-186 W (single versions), 258 W or 372 W (dual versions) Class I, IP66, ta=-40 °C ...+65 °C
Trademark (if any)	Dialight
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Vigilant LED Low Bay Vigilant LED High Bay Vigilant LED Flood Light  See general product information (page 6 up to and including page 10 of report 2218099.50) for more details
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-2-1:1979, IEC 60598-2-1:1979/AMD1:1987, IEC 60598-2-24:2013 National differences: EU Group Differences, AS, NZ
As shown in the Test Report Ref. No. which forms part of this Certificate	2218099.50, .51, .52 and .53

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

