


This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Dialight Corporation	Manufacturer: Dialight de Mexico
Address: 1501 Route 34 South Farmingdale NJ, 07727	Address: Calle Lirios S/N, Col. Carlos Pacheco Ensenada, B.C. Mexico 22830
Country: USA	Country: Mexico
Contact: Mr. Arturo Santamaria	Contact: Angel Escamilla
Phone: (732) 751-5845	Phone: 52-646-156-7080
FAX: (732) 751-3145	FAX: NA
Email: Asantamaria@dialight.com	Email: Aescamilla@dialight.com
Party Authorized To Apply Mark: Same as Manufacturer	
Report Issuing Office: Cortland, NY	
Control Number: <u>3081714</u>	Authorized by:  for Dean Davidson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s): Standard For Luminaires For Use In Hazardous (Classified) Locations [UL 844:2012 Ed.13 +R:11Mar2016] Electric Luminaires For Use In Hazardous Locations (R2014) [CSA C22.2#137:1981 Ed.1 +G1]

Product:	High Efficiency High Bay Luminaires for use in: Class I, Division 1, Group C&D, Class I, Division 2, groups C&D Class II, Division 1 Groups E-G, Class II Division 2, Groups F-G Ambient Range: -40°C to 65°C Operating Temperature Code: T4A at 65°C Ambient, T5 at 55°C Ambient Electrical Rating: 100 - 277 Vac, 50/60 Hz, 200W maximum Paint Spray Booth Approved: Model HEM (only)
Brand Name:	SafeSite High Bay Luminaires
Models:	HE; followed by C or M; followed by 7, 8, 9, or G; followed by E, L, M, N, R, W, or 7; followed by any alphanumeric character; followed by 2 or 4; followed by any alphanumeric character; followed by D or N; followed by any alphanumeric character; followed by any alphanumeric character; may be followed by N; followed by any alphanumeric character; May be followed by N.

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Dialight Corporation
Address: 1501 Route 34 South
Farmingdale NJ, 07727
Country: USA
Contact: Mr. Arturo Santamaria
Phone: (732) 751-5845
FAX: (732) 751-3145
Email: Asantamaria@dialight.com

Manufacturer: Sanmina SCI Systems de Mexico
Carretera Guadalajara - Chapala
Km. 15.5 No. 29
Address: Tlajomulco de Zuniga
Jalisco, Mexico 45640
Country: Mexico
Contact: Alejandro Rodriguez
Phone: 001-52-33-36689800 Ext. 9905
FAX: NA
Email: alejandro.rodriguez@sanmina.com

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Cortland, NY

Control Number: 5003424

Authorized by: 
for Dean Davidson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s): Standard For Luminaires For Use In Hazardous (Classified) Locations [UL 844:2012 Ed.13 +R:11Mar2016]
Electric Luminaires For Use In Hazardous Locations (R2014) [CSA C22.2#137:1981 Ed.1 +G1]

Product:	High Efficiency High Bay Luminaires for use in: Class I, Division 1, Group C&D, Class I, Division 2, groups C&D Class II, Division 1 Groups E-G, Class II Division 2, Groups F-G Ambient Range: -40°C to 65°C Operating Temperature Code: T4A at 65°C Ambient, T5 at 55°C Ambient Electrical Rating: 100 - 277 Vac, 50/60 Hz, 200W maximum Paint Spray Booth Approved: Model HEM (only)
Brand Name:	SafeSite High Bay Luminaires
Models:	HE; followed by C or M; followed by 7, 8, 9, or G; followed by E, L, M, N, R, W, or 7; followed by any alphanumeric character; followed by 2 or 4; followed by any alphanumeric character; followed by D or N; followed by any alphanumeric character; followed by any alphanumeric character; may be followed by N; followed by any alphanumeric character; May be followed by N.