Dialight

SafeSite® LED End-to-End Linear Fixture - UL 844 for Indoor and Outdoor Hazardous Applications

On when it matters most.

Products and solutions that protect your business



*Products shown above are not all certified for hazardous locations. Please visit www.dialight.com for more information.



Features & Benefits

- 5 Year full performance warranty
- L70 rated for >100,000 hours @ 25°C
- Excellent corrosion resistance
- Dual wiring boxes for easy installation
- Through wiring capability
- Instant on/off operation
- Resistant to water, salt, dust & vibration
- Universal input (120-277V AC, 50/60hz)
- Mercury free
- Temperature compensation technology for longer life

Application

The SafeSite LED Linear fixture's rugged solid state design makes it highly resistant to shock and vibration. Its fully gasketed IP66/67 rated enclosure makes it suitable for dust & wet locations, its 1598/A rating guarantees added protection from salt water spray. The SafeSite LED Linear's superior design allows for wiring and mounting versatility and ease of installation for many lighting applications.



SafeSite

Hazardous Locations Ratings

Fixed and portable fixtures for installation and use in hazardous (classified) locations Class I, Divisions 1 and 2, Groups A, B, C, and D; Class II, Division 1, Groups E, F, and G; Class II, Division 2, Groups F and G; and Class III, Divisions 1 and 2, in accordance with the National Electrical Code, NFPA 70

Classes

The classes define the general nature of hazardous material in the surrounding atmosphere.

Class	Hazardous Material in Surrounding Atmosphere
Class I	Hazardous because flammable gases or vapors are present in the air in quantities sufficient to produce explosive or ignitable mixtures.
Class II	Hazardous because combustible or conductive dusts are present.
Class III	Hazardous because ignitable fibers or flying's are present, but not likely to be in suspension in sufficient quantities to produce ignitable mixtures. Typical wood chips, cotton, flax and nylon. Group classifications are not applied to this class.

Divisions

The division defines the probability of hazardous material being present in an ignitable concentration in the surrounding atmosphere.

Division	Presence of Hazardous Material
Division 1	The substance referred to by class is present during normal conditions.
Division 2	The substance referred to by class is present only in abnormal conditions, such as a container failure or system breakdown.

Groups

The group defines the hazardous material in the surrounding atmosphere.

Group	Hazardous Material in Surrounding Atmosphere
Group A	Acetylene
Group B	Hydrogen, fuel and combustible process gases containing more than 30% hydrogen by volume or gases of equivalent hazard such as butadiene, ethylene, oxide, propylene oxide and acrolein.
Group C	Carbon monoxide, ether, hydrogen sulfide, morphline, cyclopropane, ethyl and ethylene or gases of equivalent hazard.
Group D	Gasoline, acetone, ammonia, benzene, butane, cyclopropane, ethanol, hexane, methanol, methane, vinyl chloride, natural gas, naphtha, propane or gases of equivalent hazard.
Group E	Combustible metal dusts, including aluminum, magnesium and their commercial alloys or other combustible dusts whose particle size, abrasiveness and conductivity present similar hazards in connection with electrical equipment.
Group F	Carbonaceous dusts, carbon black, coal black, charcoal, coal or coke dusts that have more than 8% total entrapped volatiles or dusts that have been sesitized by other material so they present an explosion hazard.
Group G	🔹 🔹 🔍 🔵 🔵 Flour dust, grain dust, flour, starch, sugar, wood, plastic and chemicals. 🔍 🔍 🔍 🔍 🔍 🔍 🔍

http://www.engineeringtoolbox.com/hazardous-areas-classification-d_347.html

SafeSite

SafeSite® LED End-to-End Linear Fixture - UL 844 Standard Model



Certifications & Ratings


- UL1598/A
- CSA 22.2 No. 250.0
- UL844
- CSA 22.2 No. 137
- IP66/67

Class I Div. 2 Groups A, B, C, D

• NEMA 4X


- Class II Div. 1 Groups E, F, G
- Class II Div. 2 Groups F, G
- Class III

2' End - to - End Linear Dimensional



Dimensions in inches [mm]

4' End - to - End Linear Dimensional



Dimensions in inches [mm]

Temperature Ratings									
Ambient Temperature Range T4A Temperature Code	Ambient Temperature Range T5 Temperature Code								
-40°F to +149°F (-40°C to +65°C)	-40°F to +113°F (-40°C to +45°C)								

Mechanical Information: Fixture weight: 4' - 18 lbs (8.16 kg) 2' - 13 lbs (5.90 kg) Shipping weight: 4' - 20 lbs (9.07 kg)

Mounting:

2' - 15 lbs (6.80 kg) (4) 3/4" NPT openings Optional ceiling, flush or swivel mounting bracket


Electrical Specifications:

Licemean opeemeanon	age: 120 - 277V AC						
Operating voltage:	120 - 277V AC						
Power consumption:	See table						
Operating temp:	-40°F to +149°F (-40°C to +65°C)						
Harmonics:	61000-3-2						
Transient protection:	FCC Title 47, Subpart B, Section 15, Class A device. RF Immunity; 10V/m, 80MHz-1GHz						
Surge protection:	EN 61000-4-5 6kV line to line 6kV line to ground						
THD:	< 20%						
Power factor:	> 0.9						
Construction:							
Housing:	Extruded 6063 aluminum						
Finish:	Superior dual coat finish - Sealed polyester topcoat - Chemical-resistant epoxy primer						
Lens:	Polycarbonate						
Photometric Information:							
CRI:	80						
CCT:	5000 K(cool white) 4000K (neutral white)						
IES files:	Available at www.dialight.com						
All values typical unless other	wise stated (tolerance +/- 10%)						


* For information on chemical compatibility, please follow this link to reference Dialight's Chemical Compatibility Guide. www.dialight.com/pubs/MDTFCHEMRFLX001.PDF

SafeSite® LED End-to-End Linear Fixture - UL 844


Mounting Options




SafeSite® LED End-to-End Linear Fixture - UL 844 **Mounting Dimensional**




2' - Flush Mount




2' - Ceiling Mount



4' - Flush Mount



4' - Ceiling Mount



9


SafeSite[®] LED End-to-End Linear Fixture - UL 844 Ordering Information


Part Number ¹	Length	CRI	CID1	CID2	CIID1	CIID2	CIII	Voltage	Lens	ССТ	Fixture Lumens	Watt	LPW	Optical Pattern
CID2 Models														
LBD2MB3FNNNNGN	4'	80		•				120 - 277V AC	Clear	5000K (cool white)	7,500	60	125	Circular
LBD6MB3FNNNNGN	4'	80		•				120 - 277V AC	Diffused	5000K (cool white)	6,750	60	112	Circular
LAD2MB3BNNNNGN	2'	80		•				120 - 277V AC	Clear	5000K (cool white)	4,000	32	125	Circular
LAD6MB3BNNNNGN	2'	80		•				120 - 277V AC	Diffused	5000K (cool white)	3,500	32	109	Circular
CIID1 Models														
LBF2MB3FNNNNGN	4'	80			•	•	•	120 - 277V AC	Clear	5000K (cool white)	7,500	60	125	Circular
LBF6MB3FNNNNGN	4'	80			•	•	•	120 - 277V AC	Diffused	5000K (cool white)	6,750	60	112	Circular
LAF2MB3BNNNNGN	2'	80			•	•	•	120 - 277V AC	Clear	5000K (cool white)	4,000	32	125	Circular
LAF6MB3BNNNNGN	2'	80			•	•	•	120 - 277V AC	Diffused	5000K (cool white)	3,500	32	109	Circular

All values typical unless otherwise stated, Lumen values are typical (tolerance +/- 10%).

* For information on chemical compatibility, please follow this link to reference Dialight's Chemical Compatibility Guide. www.dialight.com/pubs/MDTFCHEMRFLX001.PDF Part numbers listed in the above table are cool white. For neutral white models replace the 6th character with <u>N</u>. Ex. LBD2MB3FNNNNGN becomes LBD2MB3FNNNNGN.

Light Distribution Pattern





North American HQ

1501 Route 34 South Farmingdale, NJ 07727 Tel: 732-919-3119 Fax: 732-751-5778 info@dialight.com

Copenhagen

Ejby Industrivej 91 B 2600 Glostrup Tel: +45 8877 4400 Fax: +45 3582 0099 E-mail:Info-dk@dialight.com

Houston office

16830 Barker Springs Rd Ste 407 Houston, TX 77084

EMEA HQ

Exning Road, Newmarket Suffolk, England, CB8 0AX Tel: +44 (0) 1638 665161

Australia office

38 O'Malley St Osborne Park WA 6017 Tel: +61 (0) 8 9244 7600 Fax: +61 (0) 8 9244 7601

Brazil

Av. Joao Antonio Meccatti, 1601 – Galpao 07 – Jd Planalto Jundiai – SP – 13211-223 Tel: +55 (11) 4431-4300 Fax: +55 (11) 4431-4300 Email:vendas.brasil@dialight.com

Middle East office

Level 42 Emirates Towers (Office Tower Sheikh Zayed Road Dubai, United Arab Emirates Tel: +971(0)4319 7686

Southeast Asia office

240 Macpherson Road #07-05 Pines Industrial Building Singapore 348574



Dialight reserves the right to make changes at any time in order to supply the best product possible. The most current version of this document will always be available at:

www.dialight.com/Assets/Brochures_And_Catalogs/Illumination/ MDEXLINE2EUL844X001.pc

Warranty Statement: EXCEPT FOR THE WARRANTY EXPRESSLY PROVIDED FOR IHERENVABOVE/BELOWI, DAUGH DISCLAMS ANY AND ALL OTHER WARRANTES, EXPRESS OR IMPLIED, INCLUDING, WITHOUT LIMITATION, ANY WARRANTES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, TITLE, AND NONINFRINGEMENT.