




AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Dialight Corporation	Manufacturer:	Dialight Corporation
Address:	1501 Route 34 South Farmingdale, NJ 07727	Address:	Calle Lirios S/N, Col. Carlos Pacheco Ensenada, B.C. Mexico 22830
Country:	USA	Country:	Mexico
Contact:	Frank Hertzog	Contact:	Angel Escamilla
Phone:	(732) 751-5838	Phone:	52-646-156-7080
FAX:	(732) 751-3138	FAX:	NA
Email:	FHertzog@dialight.com	Email:	Aescamilla@dialight.com
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Cortland, NY		
Control Number:	<u>3081714</u>	Authorized by:	
			for Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	ISA-12.12.01-2013 - Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations CSA C22.2 No. 213-M1987 (R 2013) - Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
Product:	The equipment is a Photocell Control Unit intended for use in: Class I, Division 2, Groups B, C, D Hazardous (Classified) Locations. Outdoor rating: Rain tight locations NEMA 4X Temperature Code: T4A (120°C) Ambient Temperature range: -40°C to +65°C (T4A) or -40°C to +55°C (T4A)



AUTHORIZATION TO MARK

Models:	Model: DHZB60-Y-Z-PEC Y=0 then 3/4" NPT; Y=1 then 1/2" NPT Z=0 then Gray; Z=1 then Orange
----------------	---



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Dialight Corporation
Address: 1501 Route 34 South
Farmingdale, NJ 07727
Country: USA
Contact: Frank Hertzog
Phone: (732) 751-5838
FAX: (732) 751-3138
Email: FHertzog@dialight.com

Manufacturer: Dialight Corporation
Address: 315 Industrial Drive
Roxboro, NC 27573
Country: USA
Contact: Rudy Lopez
Phone: (336) 597-2291
FAX: (732) 223-4832
Email: Jsargeant@dialight.com

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Cortland, NY

Control Number: 4001632

Authorized by: 
for Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	ISA-12.12.01-2013 - Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations CSA C22.2 No. 213-M1987 (R 2013) - Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
Product:	The equipment is a Photocell Control Unit intended for use in: Class I, Division 2, Groups B, C, D Hazardous (Classified) Locations. Outdoor rating: Rain tight locations NEMA 4X Temperature Code: T4A (120°C) Ambient Temperature range: -40°C to +65°C (T4A) or -40°C to +55°C (T4A)



AUTHORIZATION TO MARK

Models:	Model: DHZB60-Y-Z-PEC Y=0 then 3/4" NPT; Y=1 then 1/2" NPT Z=0 then Gray; Z=1 then Orange
----------------	---



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.


This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Dialight Corporation
Address: 1501 Route 34 South
Farmingdale, NJ 07727
Country: USA
Contact: Frank Hertzog
Phone: (732) 751-5838
FAX: (732) 751-3138
Email: FHertzog@dialight.com

Manufacturer: Dialight Europe LTD
Address: Exning Road
New Market Suffolk,
CB8 0AX
Country: United Kingdom
Contact: Trevor Mallett
Phone: 44 (0) 1638 665161
FAX: 44 (0) 1638 660718
Email: tmallett@dialight.com

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Cortland, NY

Control Number: 4001646

Authorized by: 
for Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	ISA-12.12.01-2013 - Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations CSA C22.2 No. 213-M1987 (R 2013) - Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
Product:	The equipment is a Photocell Control Unit intended for use in: Class I, Division 2, Groups B, C, D Hazardous (Classified) Locations. Outdoor rating: Rain tight locations NEMA 4X Temperature Code: T4A (120°C) Ambient Temperature range: -40°C to +65°C (T4A) or -40°C to +55°C (T4A)



AUTHORIZATION TO MARK

Models:	Model: DHZB60-Y-Z-PEC Y=0 then 3/4" NPT; Y=1 then 1/2" NPT Z=0 then Gray; Z=1 then Orange
----------------	---