



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.


This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Dialight Corporation
Address: 1501 South Route 34
Farmingdale, NJ 07727
Country: USA
Contact: Mr. Anthony Russo
Phone: 732-751-5845
FAX: 732-751-3145
Email: arusso@dialight.com

Manufacturer: Dialight Corporation
Address: Calle Lirios S/N, Col. Carlos Pacheco
Ensenada, B.C. Mexico 22830
Country: Mexico
Contact: Angel Escamilla
Phone: 52-646-156-7080
FAX: NA
Email: Aescamilla@dialight.com

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Cortland, NY

Control Number: 3081714

Authorized by: 
for Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672



AUTHORIZATION TO MARK

Luminaires (UL-1598, 3rd Edition, including revisions through October 17, 2012)

Luminaires for Use in Hazardous (Classified) Locations (UL 844, 13th Edition, June 29, 2012)

Luminaires (CSA C22.2#250.0 Issued: 2008/09/17 Ed:3 Luminaires; General Instruction No.1 2010/01/11, General Instruction No. 2 2012/10/17)

Standard(s): CSA C22.2#137 Issued: 1981/08/01 Electric Luminaires for Use in Hazardous Locations General Instruction No. 1 (R2009)

Enclosures for Electrical Equipment, Non-Environmental Considerations (UL 50, 12th Edition, Sept. 4, 2007)

Enclosures for Electrical Equipment, Environmental Considerations (UL 50E, 1st Edition, Sept. 4, 2007)

Obstruction Lights

For Use In: Class I, Division 2, Groups A - D, Class II, Division 1 and 2, Groups E, F, G Hazardous Locations

Product: Operating Temperature Code: T3C;
Ambient Temperature Range: -40°C to +55°C
Operating Temperature Code: T4;
Ambient Temperature Range: -40°C to +40°C

Models: RTO-**ABZC**-00**X** where:

A can be 0, 2, A, B, D or E

B can be W, B, G, R, or Y

C can be 7 or 8

X can be 1, 2, 4 or 5

Z can be 0 or 1

Models:



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.


This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Dialight Corporation
Address: 1501 South Route 34
Farmingdale, NJ 07727
Country: USA
Contact: Mr. Anthony Russo
Phone: 732-751-5845
FAX: 732-751-3145
Email: arusso@dialight.com

Manufacturer: Dialight Corporation
Address: 315 Industrial Drive
Roxboro, NC 27573
Country: USA
Contact: Rudy Lopez
Phone: (336) 597-2291
FAX: (732) 223-4832
Email: rlopez@dialight.com

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Cortland, NY

Control Number: 4001632

Authorized by: 
for Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672



AUTHORIZATION TO MARK

Luminaires (UL-1598, 3rd Edition, including revisions through October 17, 2012)

Luminaires for Use in Hazardous (Classified) Locations (UL 844, 13th Edition, June 29, 2012)

Luminaires (CSA C22.2#250.0 Issued: 2008/09/17 Ed:3 Luminaires; General Instruction No.1 2010/01/11, General Instruction No. 2 2012/10/17)

Standard(s): CSA C22.2#137 Issued: 1981/08/01 Electric Luminaires for Use in Hazardous Locations General Instruction No. 1 (R2009)

Enclosures for Electrical Equipment, Non-Environmental Considerations (UL 50, 12th Edition, Sept. 4, 2007)

Enclosures for Electrical Equipment, Environmental Considerations (UL 50E, 1st Edition, Sept. 4, 2007)

Obstruction Lights

For Use In: Class I, Division 2, Groups A - D, Class II, Division 1 and 2, Groups E, F, G Hazardous Locations

Product: Operating Temperature Code: T3C;
Ambient Temperature Range: -40°C to +55°C
Operating Temperature Code: T4;
Ambient Temperature Range: -40°C to +40°C

Models: RTO-**ABZC**-00**X** where:

A can be 0, 2, A, B, D or E

B can be W, B, G, R, or Y

C can be 7 or 8

X can be 1, 2, 4 or 5

Z can be 0 or 1

Models:



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.


This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Dialight Corporation
Address: 1501 South Route 34
Farmingdale, NJ 07727
Country: USA
Contact: Mr. Anthony Russo
Phone: 732-751-5845
FAX: 732-751-3145
Email: arusso@dialight.com

Manufacturer: Dialight Europe LTD
Address: Exning Road
New Market Suffolk, CB80AX
Country: United Kingdom
Contact: Chris Stanton
Phone: 44 (0) 1638 665161
FAX: 44 (0) 1638 660718
Email: cstanton@dialight.com

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Cortland, NY

Control Number: 4001646

Authorized by: 
for Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672



AUTHORIZATION TO MARK

Luminaires (UL-1598, 3rd Edition, including revisions through October 17, 2012)

Luminaires for Use in Hazardous (Classified) Locations (UL 844, 13th Edition, June 29, 2012)

Luminaires (CSA C22.2#250.0 Issued: 2008/09/17 Ed:3 Luminaires; General Instruction No.1 2010/01/11, General Instruction No. 2 2012/10/17)

Standard(s): CSA C22.2#137 Issued: 1981/08/01 Electric Luminaires for Use in Hazardous Locations General Instruction No. 1 (R2009)

Enclosures for Electrical Equipment, Non-Environmental Considerations (UL 50, 12th Edition, Sept. 4, 2007)

Enclosures for Electrical Equipment, Environmental Considerations (UL 50E, 1st Edition, Sept. 4, 2007)

Obstruction Lights

For Use In: Class I, Division 2, Groups A - D, Class II, Division 1 and 2, Groups E, F, G Hazardous Locations

Product: Operating Temperature Code: T3C;
Ambient Temperature Range: -40°C to +55°C
Operating Temperature Code: T4;
Ambient Temperature Range: -40°C to +40°C

Models: RTO-**ABZC**-00**X** where:

A can be 0, 2, A, B, D or E

B can be W, B, G, R, or Y

C can be 7 or 8

X can be 1, 2, 4 or 5

Z can be 0 or 1

Models: