

ATTESTATION OF CONFORMITY

Issued to: Dialight
1501 Route 34 South
Farmingdale, New Jersey NJ 07727
United States Of America

For the product: Stainless steel LED linear luminaire for industrial areas

Trade name: Dialight

LED luminaire
Type/Model: EL-1C3M-SSCB-CR, EL-1N3M-SSCB: two foot
EL-1N3R-SSCB, EL-1C3R-SSCB: four foot

Ratings: Uin 100-277 V AC, 50/60 Hz, Ta: -20 °C to +60 °C, IP66/67
two foot: 32 W, four foot: 64 W

Lifetime(L_xB_y):

Temperature	L ₉₀ / B ₁₀
25 °C	75.000 h
60° C	50.000 h

Temperature	L ₇₀ – B ₅₀
25° C	150.000 h
60° C	100.000 h

LED module
Type/Model: Z85-001731N correlated colour temperature 4000K
Z85-001731C correlated colour temperature 5000K

Ratings: Current 350 mA, colour 4000K and 5000K

Manufactured by: Dialight Dialight, Exning Road, Newmarket, Suffolk, CB8 0AX, England


This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file nos. 2199405.50 and 2199405.51.

This Attestation implies that the examined types are in accordance with the standards designated under the IEC/PAS 62717(ed.1) and IEC/PAS 62722-2-1(ed.1) used in conjunction with IEC/PAS 62722-1. The examination has been carried out on specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 10 April 2017

Number: 2199405.01-AOC

DEKRA Certification B.V.



H.R.M. Barends
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed