8 Cootamundra Cres.
Blackburn VIC 3130
AUSTRALIA
+61 (0)430 412 380
my@anzcompliance.com.au



ANZ Electrical Compliance ABN: 76 310 261 826

Certificate No.: POC20237

PROOF OF COMPLIANCE

This certificate is issued to confirm that ANZ Electrical Compliance has certified the equipment described herein have comply with the Australian and/or New Zealand legislative requirements as listed below.

Certificate Holder: Dialight Corporation

1501 Route 34 South Farmingdale NJ 07727

U.S.A.

Product: Highbay LED Luminaire

Trade Name / Manufacturer: Vigilant

Model(s): H7-E-*-*-*-*-*-G-N

 $1^{\text{st *}}=2,\,4$ or 7, denotes Lens options; $2^{\text{nd *}}=M$ or N, denotes Reflector options; $3^{\text{rd *}}=C,\,N,\,W,\,B$ or L, denotes CCT & CRI; $4^{\text{th *}}=2,\,3,\,B,\,C$ or D, denotes Operating voltages;

5th * = K, N or R, denotes Lumen types; 6th * = D or N, denotes Controls; 7th * = H or N, denotes Mounting options;

8th * = N, T, U, V or W, denotes Hardware accessories;

 $9^{th} * = N \text{ or } Z$, denotes Electrical accessories.

Ratings: 120-277 Va.c. or 347-480 Va.c., 50/60 Hz

Max. 508 W, Class I, IP66 / IP67, ta: 65 °C

Conditions: Agency Agreement to be signed between ANZ Electrical

Compliance and any Local Distributer offering the product

for sale in Australia and/or New Zealand.

Countries and Legislations: Australia: ESV, ACMA

New Zealand: WorkSafe NZ, RSM

Compliance Details: Refer to Continuation Sheet 1

Required Regulatory Markings: RCM

Issue Date: 23 December 2020

Expiry Date: 23 December 2025

ANZ Electrical Compliance

8 Cootamundra Cres. Blackburn VIC 3130 AUSTRALIA +61 (0)430 412 380 my@anzcompliance.com.au



ANZ Electrical Compliance ABN: 76 310 261 826

Certificate No.: POC20237

PROOF OF COMPLIANCE

Continuation Sheet 1

Legislative Requirements	Compliance Details
Electrical Safety (EESS)	Equipment Level: Out of scope (not for Household use) Registered on EESS: N/A Test Report No.: 104335072CRT-001 Complied Standard(s): AS/NZS 60598.2.1:2014 +A1 +A2 AS/NZS 60598.1:2017 +A1
ACMA/RSM (EMC)	Compliance Level: AU: 2 (Medium Risk); NZ: 2 SDoC Document: Yes, Responsible supplier E7663 Test Report No.: 104408139BOX-001 Complied Standard(s): CISPR 15:2018

Issue Date: 23 December 2020 **Expiry Date:** 23 December 2025

ANZ Electrical Compliance