

8 Cootamundra Cres.
Blackburn VIC 3130
AUSTRALIA
+61 (0)430 412 380
my@anzcompliance.com.au



Certificate No.: POC21282

PROOF OF COMPLIANCE

This certificate is issued to confirm that ANZ Electrical Compliance has certified the equipment described herein have comply with the Australian and/or New Zealand legislative requirements as listed below.

Certificate Holder: Dialight Corporation
1501 Route 34 South
Farmingdale NJ 07727
U.S.A.

Product: LED Floodlight Luminaire

Trade Name / Manufacturer: Dialight, ProSite

Model(s): F1E*****N**N, F2E*****N**N
1st * = 4, 7 or N, denotes Lens options;
2nd * = 2, 4, 5, 6, 7, F or J, denotes Optics;
3rd * = A, F, B, L, C, N or W, denotes CCT & CRI;
4th * = 2, 5, 8 or 9, denotes Operating voltage;
5th * = B, C, E, F, H, L or N, denotes Lumen output range;
6th * = D or S, denotes Controls;
7th * = E, F or S, denotes Mounting options;
8th * = U or V, denotes Electrical options;
9th * = G or Z, denotes Finish.

Ratings: 100-277 Va.c., 50/60 Hz or 120-250 Vd.c.
(for F*E***2***N**N, F*E***8***N**N)
347-415 Va.c., 50/60 Hz (for F*E***5***N**N, F*E***9***N**N)
Max. 500 W, Class I, IP66/67, ta: 65 °C

Conditions: Agency Agreement to be signed between ANZ Electrical Compliance and any Local Distributer offering the product for sale in Australia and/or New Zealand.

Countries and Legislations: Australia: ESV, ACMA
New Zealand: WorkSafe NZ, RSM

Compliance Details: Refer to Continuation Sheet 1

Required Regulatory Markings: RCM

Issue Date: 26 July 2021

Expiry Date: 26 July 2026

ANZ Electrical Compliance

8 Cootamundra Cres.
Blackburn VIC 3130
AUSTRALIA
+61 (0)430 412 380
my@anzcompliance.com.au



Certificate No.: POC21282

PROOF OF COMPLIANCE

Continuation Sheet 1

Legislative Requirements	Compliance Details
Electrical Safety (EESS)	Equipment Level: Out of scope (not for Household use) Registered on EESS: N/A Test Report No.: 104525921CRT-001B Complied Standard(s): AS/NZS 60598.2.1:2014 +A1 +A2 AS/NZS 60598.1:2017 +A1
ACMA/RSM (EMC)	Compliance Level: AU: 2 (Medium Risk); NZ: 2 SDoC Document: Yes, Responsible supplier E7663 Test Report No.: 104553270DAL-001, 104553270DAL-002, 104553270DAL-003 Complied Standard(s): CISPR 15:2018

Issue Date: 26 July 2021

Expiry Date: 26 July 2026



ANZ Electrical Compliance