



## UNITED KINGDOM CONFORMITY ASSESSMENT

### UK TYPE EXAMINATION CERTIFICATE

Equipment Intended for use in Potentially Explosive Atmospheres

UKSI 2016:1107 (as amended) – Schedule 3A, Part 1

Certificate Number: **CSAE 21UKEX9735X** Issue: **0**

Product: **SafeSite Bulkhead Luminaire**

Manufacturer: **Dialight Corporation**

Address: **1501 Route 34 South  
Farmingdale  
New Jersey 07727  
USA**

This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

CSA Group Testing UK Limited, Approved Body number 0518, in accordance with Regulation 42 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations. The examination and test results are recorded in the confidential reports listed in Section 14.2.

Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN IEC 60079-0:2018      EN 60079-31:2014**

Except in respect of those requirements listed at Section 16 of the schedule to this certificate. The above standards may not appear on the UKAS Scope of Accreditation, but have been added through flexible scope of accreditation, which is available on request.

If the sign 'X' is placed after the certificate number, it indicates that the product is subject to Specific Conditions of Use identified in the schedule to this certificate.

This UK TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Regulations apply to the manufacturing process and supply of this product. These are not covered by this certificate.

The marking of this product shall be in accordance with Regulation 41 and include the following:



II 2D

Ex tb IIIC 95°C/T130°C Db

Ta - -20°C to +55°C for T5 and 95°C

Ta = -40°C to +65°C for T4 and 130°C

Name: J A May

Title: Director of Operations



**UKUK  
CANI**

CSA Group Testing UK Ltd., Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, UK  
This certificate and its schedules may only be reproduced in its entirety and without change

Certificate No. CSAE21UKEX9735X

DQD544.21 Issue 2 (2021-04-23)

Page 1 of 7



## SCHEDULE

### UK TYPE EXAMINATION CERTIFICATE

CSAE 21UKEX9735X

Issue 0

#### 13 DESCRIPTION OF PRODUCT

The BH\*\*\*\*\*, BP\*\*\*\*\* AND BZ\*\*\*\*\* series SafeSite Bulkhead have an aluminium enclosure which consists of an aluminium (top and bottom) housing, and a window (lens cover) which is made of plastic (clear/diffused). The enclosure (top and bottom) is fixed by four M6x1x40 stainless steel socket head type screws. The plastic window (lens cover) is secured within the aluminium enclosure by six M4x10 screws. There are two terminal block located, inside the aluminium enclosure, one on each side of the LED driver. The bottom enclosure housing can have upto four cable entries (two on each side) which are used to install M20 certified cable glands or stopping plugs with suitable IP code.

The third character in the model name distinguish a Zone 1/21 version from a Zone 2/Zone 22 version. See model designation below. The Zone 1/Zone 21 version is identified by third character (A) and Zone 2 /Zone 22 version is identified by third character (B).

Zone 1/21 version and Zone 2/22 version are identical to each other with the following difference:

- The light engine, hall sensor PCB and battery pack indicator PCB are all encapsulated for Zone 1/21 version.
- For Zone 2/22, light engine is not potted.
- Different LED drivers. The driver for Zone 2/22 version is only "ec" hence it cannot be used for Zone 1/21 version. The driver for Zone 1/21 version is "eb" "mb" and can be used for Zone 2/22 version.

For Zone 2/22 version, the light engine, hall sensor PCB, battery indicator PCB complies with "ec" requirements. The terminal block (certified as a component as "eb"), battery pack and connectors complies with "eb". The enclosure complies with "eb" and "tb". The power supply is certified as a component using "ec".

The following terminal blocks are installed in the lower enclosure for installation:

Terminal Blocks			
Manufacturer	Type	Certificate No.	Code
WAGO Kontakttechnik GmbH	WAGO 4 conductor device connector type 862-****/999-950	PTB 03 ATEX 1189U	Ex eb IIC Gb Ex eb I Mb
WAGO Kontakttechnik GmbH	WAGO type PE & Through terminal blocks type TOP JOB S2004-*** and type TOP JOB S 2004-***7 series	PTB 05 ATEX 1095U	Ex eb IIC Gb Ex eb I Mb

The following certified stopping plug are installed at two side walls of lower enclosure for installation:



**UKUK  
CANI**

CSA Group Testing UK Ltd., Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, UK  
This certificate and its schedules may only be reproduced in its entirety and without change

DQD544.21 Issue 2 (2021-04-23)

Page 2 of 7

## SCHEDULE

### UK TYPE EXAMINATION CERTIFICATE

CSAE 21UKEX9735X

Issue 0

Stopping Plug			
Manufacturer	Type	Certificate No.	Code
Hummel AG	type V-Ex, V-MS-*, V-INOX- * (blanking elements)	DMT 03 ATEX E 049	Ex eb IIC Gb Ex ta IIIC Da

A driver with protection type with an or Ex ec is installed inside the lower enclosure housing which has been certified separately as an Ex component, the detail information of certification listed as below:

Driver	Type	Certificate No.	Code
Dialight Corporation	8850***1**8**	Sira 19ATEX5244U	Ex eb mb IIC Gb
Dialight Corporation	8850*****4**	Sira 19ATEX4141U	Ex ec IIC Gc

The Ni-MH battery packs are an optional part which are installed inside the aluminium lower enclosure housing. The specification of battery packs is 7.2Vdc/6Ah.

LEDs are encapsulated with the optics part which is made of plastic and the heatsink by potted compound and installed inside the upper housing. There are 114 LEDs (White) or 68 LEDS (Green/Amber) for all models.

The luminaire can be mounted via flush bracket, angle bracket (30°) or an adjustable mounting bracket for different installation angles.

#### Rating:

##### Voltage:

100Vac – 277Vac ,50Hz/60Hz;

230Vac/240Vac 50Hz;

120Vac 60Hz;

120Vdc – 250Vdc;

##### Max. Power:

BH \*\*\*\*\* series: 49W Max.

BP \*\*\*\*\* series: 49W Max.

BZ \*\*\*\*\* series: 49W Max.

## SCHEDULE

### UK TYPE EXAMINATION CERTIFICATE

CSAE 21UKEX9735X

Issue 0

Ambient temperature:

Type	Ambient Temperature
BH*****E, BH*****F, BH*****G,  BP*****E, BP*****F, BP*****G,  BZ*****E, BZ*****F, BZ*****G,  (with battery pack)	-20°C to 55°C
BH*****N BP*****N BZ*****N  (without battery pack)	-40°C to 65°C

Temperature Class:

Ambient Temperature	T-code
-20°C to 55°C	T5 and T95°C
-40°C to 65°C	T4 and T130°C

Model designation of BH\*\*\*\*\*, BP\*\*\*\*\* AND BZ\*\*\*\*\* are as follows:

Model	Type designation key	Designator & application
BH*****, BP***** AND BZ*****	1st and 2nd character: Product Series	BH: Bulkhead BP: Bulkhead – Polemount (35mm spigot entry) BZ: Bulkhead – Polemount (44mm spigot entry)
	3rd character: Certification	A: ATEX/IECEX Zone 1, 21 B: ATEX/IECEX Zone 2, 22
	4th character: Lens Options	4: Polycarbonate - Clear 5: Polycarbonate – Diffused 6: Polycarbonate - Dome
	5th character: Optics	B: 360 U: Ultra wide (Type I)

## SCHEDULE

### UK TYPE EXAMINATION CERTIFICATE

CSAE 21UKEX9735X

Issue 0

Model	Type designation key	Designator & application
	6th character: CCT & CRI	C: Cool White 5000K - 80 CRI N: Neutral White 4000K - 80 CRI W: Warm White 2700K - 80 CRI G: Green A: Amber
	7th character: Operating Voltage	1: 110/120 VAC Battery Backup 2: 100 - 277 VAC/120-250 VDC G: 230/240 VAC Battery Backup
	8th character: Lumen Output Range	3: 2000 – 3000 Lumens 5: 4001 – 5000 Lumens 6: 5001 – 6000 Lumens
	9th character: Controls	N: No Options
	10th character: Mounting Options	F: Flush Bracket N: No Mounting
	11th character: Hardware/Cable Options	N: Standard (1 entry pole mount – M25) N: Standard 2 at one end M20 Entry G: Standard (2+2) at ends M20 Entry
	12th character: Electrical Options	V: Terminal Block – Push Down – 4mm U: Terminal Block – Spring Cage – 6mm
	13th character: Finish	G: Grey Y: Yellow O: Orange W: White
	14th character: Battery Backup	E: 60 min, Integrated (Emergency) F: 90 min, Integrated, (Emergency) G: 180 min, Integrated, (Emergency) N: Standard, No Battery

#### 14 DESCRIPTIVE DOCUMENTS

##### 14.1 Drawings

Refer to Certificate Annexe.

##### 14.2 Associated Reports and Certificate History

Issue	Date	Report number	Comment
0	16 February 2022	R80096715A	The release of the prime certificate.

#### 15 SPECIFIC CONDITIONS OF USE (denoted by X after the certificate number)

- 15.1 The equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.

## SCHEDULE

### UK TYPE EXAMINATION CERTIFICATE

CSAE 21UKEX9735X

Issue 0

- 15.2 All cable entry holes shall be fitted with an ATEX certified cable gland or an ATEX certified stopping plug that is suitable for the application. The type of cable, glands and stopping plugs shall have temperature ratings of at least 70°C.
- 15.3 The terminals shall only be fitted with wires that have cross sectional area falling within the following limitations:
- WAGO 2004-conductor series terminals: single-core, finely stranded and standard: min. 0.5 mm<sup>2</sup> to 6 mm<sup>2</sup>
  - WAGO 862-conductor series terminals: single-core, finely stranded and standard: min. 0.5 mm<sup>2</sup> to 4 mm<sup>2</sup>
- 15.4 The tighten torque of the screws used to fix enclosure shall be equal to 5.0±0.5Nm.
- 15.5 The equipment shall be installed such that the supply cable is protected from mechanical damage. The cable shall not be subjected to tension or torque. If the cable is to be terminated within an explosive atmosphere then the free end shall be terminated in a suitably certified termination facility.
- 15.6 Use only replaceable battery pack 9100BHD000100.
- 15.7 Clean the luminaire regularly to prevent dust accumulation.
- 15.8 IP64 was followed in accordance with IEC/EN 60079-0, IEC/EN 60079-7 and IEC 60079-31.
- 15.9 Temperature code depends on ambient temperature as follows:

T-code	Ambient Temperature
T5 and T95°C	-20°C to 55°C
T4 and T130°C	-40°C to 65°C

Note: BH\*\*\*\*\*E, BH\*\*\*\*\*F, BH\*\*\*\*\*G, BP\*\*\*\*\*E, BP\*\*\*\*\*F, BP\*\*\*\*\*G, BZ\*\*\*\*\*E, BZ\*\*\*\*\*F, BZ\*\*\*\*\*G, luminaire can be used in ambient temperature "-20°C to 55°C" only.

- 15.10 The manufacturer shall take all reasonable steps to ensure that the user/installer complies with the special conditions for certification associated with the terminal block. In addition, the manufacturer shall provide the user/installer with an appropriate copy of the certificate for each certified terminal that is fitted to the terminal enclosure.

### 16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS (REGULATIONS SCHEDULE 1)

In addition to the Essential Health and Safety Requirements covered by the standards listed in Section 9, all other requirements are demonstrated in the relevant reports.



## SCHEDULE

### UK TYPE EXAMINATION CERTIFICATE

CSAE 21UKEX9735X

Issue 0

#### 17 PRODUCTION CONTROL

- 17.1 Holders of this certificate are required to comply with production control requirements defined in Schedule 3A, as applicable, and CSA Group Testing UK Regulations for Certificate Holders
- 17.2 The manufacturer shall take all reasonable steps to ensure that the user/installer complies with the special conditions for certification associated with the terminal block. In addition, the manufacturer shall provide the user/installer with an appropriate copy of the certificate for each certified terminal that is fitted to the terminal enclosure.
- 17.3 The manufacturer shall take all reasonable steps to ensure that the user/installer complies with the special conditions for certification associated with the terminal block. In addition, the manufacturer shall provide the user/installer with an appropriate copy of the certificate for each certified terminal that is fitted to the terminal enclosure.



**UK UK  
CANI**



## Certificate Annexe

Certificate Number: CSAE 21UKEX9735X  
Product: SafeSite Bulkhead Luminaire  
Manufacturer: Dialight Corporation

---

### Issue 0

Drawing	Sheets	Rev.	Date	Title
8854bhd000200	1 to 17	-	20 Jan 2022	BHD Zone 2 Luminaire



**UK UK**  
**CANI**

CSA Group Testing UK Ltd., Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, UK  
This certificate and its schedules may only be reproduced in its entirety and without change  
DQD544.21 Issue 2 (2021-04-23)  
Page 1 of 1