



1 TYPE EXAMINATION CERTIFICATE

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: CSANe 21ATEX3246X Issue: 0

4 Equipment: SafeSite Bulkhead Luminaire

5 Applicant: Dialight Corporation

6 Address: 1501 Route 34 South

Farmingdale

New Jersey 07727

USA

- 7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- 8 CSA Group Netherlands B.V., certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design of Category 3 equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN IEC 60079-0:2018

EN IEC 60079-7:2015+A1:2018

EN 60079-31:2014

- If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.
- This Type Examination Certificate relates only to the design of the specified equipment, and not to specific items of equipment subsequently manufactured. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.
- 12 The marking of the equipment shall include the following:



II 3GD Ex ec IIC T5/T4 Gc Ex tc IIIC 95°C/T130°C Dc

Ta = -20°C to +55°C for T5 and 95°C Ta = -40°C to +65°C for T4 and 130°C

Project Number 80096716

Signed: J A May

Title: Director of Operations







TYPE EXAMINATION CERTIFICATE

CSANe 21ATEX3246X Issue 0

13 DESCRIPTION OF EQUIPMENT

The BH********, BP********* AND BZ******* series SafeSite Bulkhead have an aluminium enclosure which consists of an aluminium (top and bottom) housing, and a window (lens cover) which is made of plastic (clear/diffused). The enclosure (top and bottom) is fixed by four M6x1x40 stainless steel socket head type screws. The plastic window (lens cover) is secured within the aluminium enclosure by six M4x10 screws. There are two terminal block located, inside the aluminium enclosure, one on each side of the LED driver. The bottom enclosure housing can have upto four cable entries (two on each side) which are used to install M20 certified cable glands or stopping plugs with suitable IP code.

The third character in the model name distinguish a Zone 1/21 version from a Zone 2/Zone 22 version. See model designation below. The Zone 1/Zone 21 version is identified by third character (A) and Zone 2 /Zone 22 version is identified by third character (B).

Zone 1/21 version and Zone 2/22 version are identical to each other with the following difference:

- a) The light engine, hall sensor PCB and battery pack indicator PCB are all encapsulated for Zone 1/21 version.
- b) For Zone 2/22, light engine is not potted.
- c) Different LED drivers. The driver for Zone 2/22 version is only "ec" hence it cannot be used for Zone 1/21 version. The driver for Zone 1/21 version is "eb" "mb" and can be used for Zone 2/22 version.

For Zone 2/22 version, the light engine, hall sensor PCB, battery indicator PCB complies with "ec" requirements. The terminal block (certified as a component as "eb"), battery pack and connectors complies with "eb". The enclosure complies with "eb" and "tb". The power supply is certified as a component using "ec".

The following terminal blocks are installed in the lower enclosure for installation:

Terminal B	locks				
Manufactur	rer	Type	Certificate No.	Code	
WAGO	Kontakttechnik	WAGO 4 conductor device	PTB 03 ATEX 1189U	Ex eb IIC Gb	
GmbH		connector type 862-		Ex eb I Mb	
		****/999-950			
WAGO	Kontakttechnik	WAGO type PE & Through	PTB 05 ATEX 1095U	Ex eb IIC Gb	
GmbH		terminal blocks type TOP		Ex eb I Mb	
		JOB S2004-*** and type			
		TOP JOB S 2004-***7			
		series			

The following certified stopping plug are installed at two side walls of lower enclosure for installation:

Stopping Plug						
Manufacturer	Type				Certificate No.	Code
Hummel AG	type	V-Ex,	V-MS-*,	V-INOX-*	DMT 03 ATEX E 049	Ex eb IIC Gb
	(blank	(blanking elements)				Ex ta IIIC Da

A driver with protection type with Ex ec is installed inside the lower enclosure housing which has been certified separately as an Ex component, the detail information of certification listed as below:





TYPE EXAMINATION CERTIFICATE

CSANe 21ATEX3246X Issue 0

Driver	Туре	Certificate No.	Code
Dialight Corporation	8850***1**8**	Sira 19ATEX5244U	Ex eb mb IIC Gb
Dialight Corporation	8850*****4**	Sira 19ATEX4141U	Ex ec IIC Gc

The Ni-MH battery packs are an optional part which are installed inside the aluminum lower enclosure housing. The specification of battery packs is 7.2Vdc/6Ah.

LEDs are encapsulated with the optics part which is made of plastic and the heatsink by potted compound and installed inside the upper housing. There are 114 LEDs (White) or 68 LEDS (Green/Amber) for all models.

The luminaire can be mounted via flush bracket, angle bracket (30°) or an adjustable mounting bracket for different installation angles.

Rating:

Voltage:

100Vac - 277Vac ,50Hz/60Hz;

230Vac/240Vac 50Hz;

120Vac 60Hz;

120Vdc - 250Vdc;

Max. Power:

BH ******* series: 49W Max. BP ****** series: 49W Max. BZ ****** series: 49W Max.

Ambient temperature:

Type	Ambient Temperature
BH******E,	-20°C to 55°C
BH*******F,	
BH******G,	
BP******E,	
BP********F,	
BP******G,	
BZ******E,	
BZ*******F,	
BZ******G,	
(with battery pack)	
BH*******N	-40°C to 65°C
BP*******N	
BZ*******N	
(without battery pack)	





TYPE EXAMINATION CERTIFICATE

CSANe 21ATEX3246X Issue 0

Temperature Class:

Ambient Temperature	T-code
-20°C to 55°C	T5 and T95°C
-40°C to 65°C	T4 and T130°C

Model designation of BH*********, BP********* AND BZ******* are as follows:

Model	Type designation key	Designator & application
BH********	1st and 2nd	Designator & application BH: Bulkhead
BP*****AND	character:	BP: Bulkhead – Polemount (35mm spigot entry)
B7********	Product Series	BZ: Bulkhead – Polemount (44mm spigot entry)
BZ	3rd character:	A: ATEX/IECEx Zone 1, 21
	Certification	·
		B: ATEX/IECEx Zone 2, 22
	4th character:	4: Polycarbonate - Clear
	Lens Options	5: Polycarbonate – Diffused
	F.I. I	6: Polycarbonate - Dome
	5th character:	B: 360
	Optics	U: Ultra wide (Type I)
	6th character:	C: Cool White 5000K - 80 CRI
	CCT & CRI	N: Neutral White 4000K - 80 CRI
		W: Warm White 2700K - 80 CRI
		G: Green
		A: Amber
	7th character:	1: 110/120 VAC Battery Backup
	Operating Voltage	2: 100 - 277 VAC/120-250 VDC
		G: 230/240 VAC Battery Backup
	8th character:	3: 2000 – 3000 Lumens
	Lumen Output Range	5: 4001 – 5000 Lumens
		6: 5001 – 6000 Lumens
	9th character:	N: No Options
	Controls	
	10th character:	F: Flush Bracket
	Mounting Options	N: No Mounting
	11th character:	N: Standard (1 entry pole mount – M25)
	Hardware/Cable	N: Standard 2 at one end M20 Entry
	Options	G: Standard (2+2) at ends M20 Entry
	12th character:	V: Terminal Block – Push Down – 4mm
	Electrical Options	U: Terminal Block - Spring Cage - 6mm
	13th character:	G: Grey
	Finish	Y: Yellow
		O: Orange
		W: White





TYPE EXAMINATION CERTIFICATE

CSANe 21ATEX3246X Issue 0

Model	Type designation key	Designator & application
	14th character:	E: 60 min, Integrated (Emergency)
	Battery Backup	F: 90 min, Integrated, (Emergency)
		G: 180 min, Integrated, (Emergency)
		N: Standard, No Battery

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Reports and Certificate History

Issue	Date	Report number	Comment
0	16 February 2022	R80096713A	The release of the prime certificate.

- 15 SPECIFIC CONDITIONS OF USE (denoted by X after the certificate number)
- 15.1 The equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.
- 15.2 All cable entry holes shall be fitted with either an ATEX certified cable gland or an ATEX certified stopping plug that is suitable for the application. The type of cable, glands and stopping plugs shall have temperature ratings of at least 70°C.
- 15.3 The terminals shall only be fitted with wires that have cross sectional area falling within the following limitations:
 - WAGO 2004-conductor series terminals: single-core, finely stranded and standard: min. 0.5 mm² to 6 mm²
 - WAGO 862-conductor series terminals: single-core, finely stranded and standard: min. 0.5 mm² to 4 mm²
- 15.4 The tighten torque of the screws used to fix enclosure shall be equal to 5.0±0.5Nm.
- The equipment shall be installed such that the supply cable is protected from mechanical damage. The cable shall not be subjected to tension or torque. If the cable is to be terminated within an explosive atmosphere then the free end shall be terminated in a suitably certified termination facility.
- 15.6 Use only replaceable battery pack 9100BHD000100.
- 15.7 Clean the luminaire regularly to prevent dust accumulation.
- 15.8 IP64 was followed in accordance with IEC/EN 60079-0, IEC/EN 60079-7 and IEC 60079-31.
- 15.9 Temperature code depends on ambient temperature as follows:

T-code	Ambient Temperature
T5 and T95°C	-20°C to 55°C
T4 and T130°C	-40°C to 65°C





TYPE EXAMINATION CERTIFICATE

CSANe 21ATEX3246X Issue 0

Note:	BH*****	****E, BH****	*****F,	BH*****	****G,	BP*****	****E,	BP***	* * * *	****	F,
BP***	******G,	BZ******	*E, BZ***	******F,	BZ****	******G,	luminair	e can	be i	used	ir
ambie	nt temperatu	re "-20°C to 55	°C" only.								

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

- 17 CONDITIONS OF MANUFACTURE
- 17.1 The use of this certificate is subject to the Regulations Applicable to Holders of CSA Certificates.
- 17.2 Holders of Type Examination Certificates are required to comply with the conformity to type requirements defined in Article 13 of Directive 2014/34/EU.
- 17.3 The equipment shall be subjected to a dielectric strength test at 1554 Vac for at least 60 s without dielectric breakdown occurring between input terminal of luminaire and the earthing, and between circuits and the non-metallic surface of the equipment (either a non-metallic enclosure or the surface of the compound). Alternatively, the test may be carried out at 1865 Vac for at least 100 ms, 2198 Vdc for at least 60 s or 2638 Vdc for at least 100 ms. Between input terminal of luminaire and the earthing, and between circuits and the non-metallic surface of the equipment (either a non-metallic enclosure or the surface of the compound). The testing base on clause 7.1 of IEC 60079-7:2017.
- 17.4 The manufacturer shall take all reasonable steps to ensure that the user/installer complies with the special conditions for certification associated with the terminal block. In addition, the manufacturer shall provide the user/installer with an appropriate copy of the certificate for each certified terminal that is fitted to the terminal enclosure.
- 17.5 The products covered by this certificate incorporate previously certified devices, it is therefore the responsibility of the manufacturer to continually monitor the status of the certification associated with these devices, and the manufacturer shall inform CSA of any modifications of the devices that may impinge upon the explosion safety design of their products.

Certificate Annexe

Certificate Number: CSANe 21ATEX3246X

Equipment: SafeSite Bulkhead Luminaire

Applicant: Dialight Corporation



Issue 0

Drawing	Sheets	Rev.	Date	Title
8854bhd000200	1 to 17	-	20 Jan 2022	BHD Zone 2 Luminaire